

Electrical Inspector leaves potential for plant to be made live.

WHAT HAPPENED

Electrical Inspector defeating mains plant isolator interlock. Panel was left open and inspector not in switch room leaving potential for plant to be made live.

LEARNING POINTS / ACTIONS TAKEN

LOCATION:	QUARRY	ALERT STATUS:	Normal
ACTIVITY:	GUARDING AND ISOLATION	DATE ISSUED:	04/06/2025 15:35:09
SUB ACTIVITY:	NO SUB ACTIVITY AVAILABLE	INCIDENT No:	04880