

INCIDENT ALERT

INCIDENT TIME: Out of hours weekend/bank holiday
COUNTY: Gloucestershire
INCIDENT No: 00002

DATE: 22/03/2012
LOCATION: Rural

Shorncote Quarry

INCIDENT DETAILS

Criminals accessed the site with a vehicle across adjoining land and by cutting the perimeter fencing. The electricity sub-station was broken into and power was disabled. Ground cables to pumps in the limestone and de-watering areas were then exposed and it is believed attached to the vehicle and dragged out of the ground. Replacement and installation of new cables £8k

POLICE REACTION

Police attended site with a forensics team

HEALTH AND SAFETY IMPLICATIONS

Electrocution

LEARNING POINTS

Frequency of perimeter security checks increased Discussions held with neighbouring landowner on access issue and site security of adjoining land.

IMAGES