

INCIDENT ALERT

LOCATION: Aggregate Dredger
ACTIVITY: Marine Operations
SUB ACTIVITY: Ship to shore

ALERT STATUS: Critical
DATE ISSUED: 22/09/06
INCIDENT No: 00118

TITLE

Oil Spill

ACCIDENT / INCIDENT DETAILS

While transferring fuel to shore generator the fuel travelled along line to ford boiler tank and overflowed onto deck and into dock.
Approx 15ltrs of mgo flowed into water

ACCIDENT / INCIDENT IMAGES

LEARNING POINTS / ACTIONS TAKEN

This incident could have been easily avoided, the valves to the fwd domestic boiler header tank should have been shut prior to carrying out this operation. Fortunately only a small quantity of fuel overflowed into docks before pumping ceased and clean up/containment operations began.
The prompt actions of ships staff and their rapid implimentation of the oil spill response procedure was noted by the local harbour authorities.
No PtW was completed.
Company bunker checklist only covers loading ops from barge and needs revising to cover bunkering from shore tanker, and discharge of oily waste as well as loading oil in barrels.

LEARNING POINTS / ACTIONS IMAGES