

Fire - Potential fire hazards identified in the area of a cement plant laboratory due to poor house keeping

WHAT HAPPENED

Large build-up of waste, outside of chemical lab, preventing access to oxygen storage. Unable to isolate gas supplies in the event of an emergency. Evidence of smoking in the area which is a "no smoking" area. Source of ignition, fuel and oxygen source all present with the potential to create a vigorous fire.

LEARNING POINTS / ACTIONS TAKEN

LOCATION:	LABORATORY	ALERT STATUS:	Normal
ACTIVITY:	MAINTENANCE & HOUSEKEEPING	DATE ISSUED:	18/09/2024 13:20:06
SUB ACTIVITY:	WALKWAYS	INCIDENT No:	04824