Fire - Potential fire hazards identified in the area of a cement plant laboratory due to poor house keeping

WHAT HAPPENED

Large build-up of waste, outside of chemical lab, preventing access to oxygen storage. Unable to isolate gas supplies in the event of an emergency. Evidence of smoking in the area which is a "no smoking" area. Source of ignition, fuel and oxygen source all present with the potential to create a vigorous fire.

LEARNING POINTS / ACTIONS TAKEN

LOCATION:	**LABORATORY**	**ALERT STATUS:**	**Normal**
ACTIVITY:	**MAINTENANCE & HOUSEKEEPING**	**DATE ISSUED:**	**18/09/2024 13:20:06**
SUB ACTIVITY:	**WALKWAYS**	**INCIDENT No:**	**04824**