

# High level of CO detected during kiln shut down

## WHAT HAPPENED

During a kiln shutdown period, high CO was detected in coal hoppers (kiln & calciner) and coal mill filter. CO build-up occurred after fuel systems had not been emptied due to a kiln stoppage after a main bag filter failure. There was a failure of the CO2 inertisation system at the same time due to suspected leaks.

## LEARNING POINTS / ACTIONS TAKEN

LOCATION:	CEMENT PLANT	ALERT STATUS:	Normal
ACTIVITY:	MAINTENANCE & HOUSEKEEPING	DATE ISSUED:	05/06/2025 11:28:17
SUB ACTIVITY:	KILNS	INCIDENT No:	04884